


Raychem SPECIFICATION GUIDELINE



T2BLUE-10 ELECTRICAL UNDERFLOOR HEATING

CONSTANT WATTAGE CABLE

- An electrical underfloor heating system shall be installed to provide a comfortable (18-27°C) floor temperature.
- The underfloor heating cables shall be the 10 W/m, two wire constant wattage cable type (to ensure negligible electromagnetic fields), with Teflon inner jacket, electrical braid, LSOH type 1 outer jacket and overall thickness of 5.5 mm, as manufactured by Pentair Thermal Management and known as Raychem T2Blue-10.
- The manufacturer shall provide a 12 year Total Care Warranty, for systems installed, tested, commissioned and registered, strictly according to their requirements, by a qualified electrician and this shall be extendable to 20 years if performed by Certified Pro installers.
- All underfloor heating cables shall be capable of a maximum circuit length of 200 m.
- All underfloor heating circuits shall be protected by an MCB (to BS EN 60898, type C/D) and RCD (30 mA sensitivity, tripping within 100 ms)

All underfloor heating circuits shall be controlled and monitored by programmable digital floor temperature sensing thermostats, named Raychem NRG-Temp, with integrated timer, economy setback and boost functions.

- All connections between the electrical supply, control panel, thermostat (s) and underfloor heating circuits shall be installed by an approved electrical contractor.



WWW.THERMAL.PENTAIR.COM

UNITED KINGDOM

Tel: 0800 969 013
Fax: 0800 968 624
salesthermaluk@pentair.com

IRELAND

Tel: 1800 654 241
Fax: 1800 654 240
salesie@pentair.com

All Pentair trademarks and logos are owned by Pentair. All other brand or product names are trademarks or registered marks of their respective owners. Because we are continuously improving our products and services, Pentair reserves the right to change specifications without prior notice. Pentair is an equal opportunity employer.

© 2013 Pentair. All Rights Reserved.